

**EAST HANOVER TOWNSHIP, LEBANON COUNTY
UNIFORM CONSTRUCTION CODE APPEALS BOARD
MEETING AGENDA
March 11, 2025 at 7:00 pm**

I. Call to Order

II. Roll Call

III. Organize

IV. Public Comments

V. New Business

a. Streamline Builders, 21 Blacksmith Lane:

Request for variance of §903.2.4 of the 2018 International Building Code (IBC), which requires an automatic sprinkler system be provided throughout all buildings containing a Group F-1 occupancy where the fire area exceeds 12,000 square feet.

VI. Adjournment